



नगर परिषद कार्यालय, बुलढाणा
जि. बुलढाणा



email:- mcbuldana@gmail.com

दूरध्वनी क्र.-07262-297462

MCB/FIRE/ 9710 /2024

Date :- 17 /12/2024

APPENDIX -XII

(Fire No - Objection Certificate)

Certified That, Swami Vivekanand Rashtriya Dnyanpeeth at Renuka Nagar ,Behind Bus Stand,Jalgaon (Jamod) Disst. Buldhana Maharashtra -443402 comprised of 00 (Zero) basement(s) 01 (One) Ground, 01 (One) First floor , And 01 (One) Second floor. Building block owned / occupied by Swami Vivekanand Rashtriya Dnyanpeeth, have completed with the fire prevention and fire safety requirements in accordance with rule of State / UT Fire Services Rule, and verified by the officers concerned of the service on 17/12/2024 in presence of Principal Sandip Ghate , Swami Vivekanand Rashtriya Dnyanpeeth and that the Building / Premises is fit for occupancy up to classes XII with effect from 17/12/2024 to 31/12/2025 for a period of one year in accordance with rule subject to compliance of the conditions as appended.

(The above NOC is Valid Up to 31/12/2025).

Issued on 17/12/2024 at Buldhana by



Signature with Seal :- _____

Name :- _____


Designation :- _____


Fire Officer
Municipal Council, Buldhana

To,

✓ The Principal,

Swami Vivekanand Rashtriya Dnyanpeeth, At Renuka Nagar ,Behind Bus Stand,Jalgaon (Jamod) Disst. Buldhana Maharashtra -443402


President,
Navyug Shikshan Sanstha,
Jalgaon(Jamod)


Principal,
Swami Vivekanand Rashtriya
Dnyanpeeth, Jalgaon(Jamod)
Dist Buldhana.





नगर परिषद कार्यालय, बुलढाणा
जि.बुलढाणा

75
आज़ादी का
अमृत महोत्सव

email:- mcbuldana@gmail.com

दूरध्वनी क्र.-07262-242318

MCB / FIRE / 9710 /2024

DATE:- 17/12/2024

(Fire No – Objection Certificate)

To,

✓ The Principal

Swami Vivekanand Rashtriya Dnyanpeeth

At Renuka Nagar Behind Bus Stanad ,Jalgaon (Jamod)

Tq. Jalgaon (Jamod) Disst. Buldhana Maharashtra -443402

Sub : Grand of " Fire No Objection Certificate " for your Educational Building

Ref : 1. Your Application No. 57/2024 Date 17/12/2024

2. Certificate Submitted by License Agency Kohinoor Safety Services ,Mumbai

Vide their letter dated 28/09/2024

This has reference to the above .This office has No Objection for Fire,approval for Educational Building Swami Vivekanand Rashtriya Dnyanpeeth, Nazul At Renuka Nagar Behind Bus Stanad ,Jalgaon (Jamod) Tq. Jalgaon (Jamod) Disst. Buldhana Maharashtra - 443402 Since the fire fighting arrangements provided is installed by License Agency i.e. Kohinoor Safety Services ,Mumbai No.MFS/LA/RF-10/RD-10 issued by Directorate of Maharashtra fire Service and has submitted Certificate in " Form A " prescribed in Maharashtra Fire Prevention and life safety Measure rules 2009, this office is issuing a " No Objection Certificate " for your Educational building .

Fire fighting System found in the premises are given below arrangements

Sr.No.	Equipment Installed	Quantity
1	900 LPM Pump	01
2	450 LPM Pump	01
3	Fire Hose Reel Hose 30 Mtrs	08
4	Hydrant Valves	08

President,

Navyug Shikshan Sanstha,
Jalgaon(Jamod)

Principal,

Swami Vivekanand Rashtriya
Dnyanpeeth,Jalgaon(Jamod)



5	Fire Services Inlet	02
6	Fire Extinguishers ABC 06 Kg	10
7	Fire Extinguishers Co2 4.5 Kg	02
8	Hose Box	08
9	Short Branch Pipe	08
10	4 Zone Fire Alarm Panel	01
11	MCP	03
12	Hooter	03

Statutory Provisions Under Maharashtra Fire Prevention and life safety Measure Act ,2006.

1. Under section 3 of "Maharashtra Fire Prevention and life safety Measure Act ,2006 " (hereinafter referred to as said Act). The applicant shall comply with all the Fire and life safety measures adhering to National Building Code of India ,2016 and as amended from time to time failing which it shall be treated as a violation of the said Act.

2. It is presumed that you have completed the work adhering to the provisions under Section-3 of the said Act.


3. Under sub – section (3) of Section 3, it is responsibility of the Owner or the Occupier as the case maybe, shall furnish to the Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January and July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

4. Under sub section (4) of Section 3, no person shall tamper with, alter, remove or cause any injury or damage to any fire prevention and life safety equipment installed in any such building or part thereof or instigate any person to do so .


The Fire Fighting System provided by you in the premises as per No-Objection Certificate shall be well maintained and shall be kept in tip - top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice and you will be solely responsible to loss of property if any, which may please be noted.

The condition mentioned in the " No - Objection Certificate " will remain unchanged. The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. If any change of Activity or Transfer of Plot or any future expansion, No - Objection Certificate from this office is essential.

(The above NOC is Valid Up to 31/12/2025).


President,
Navyug Shikshan Sanstha,
Jalgaon(Jamod)




Fire Officer
Municipal Council, Buldhane
Principal,
Swami Vivekanand Rasntry,
Dnyanpeeth, Jalgaon(Jamod)